



Mammoth Fire Protection Systems

Incorporated

176 Walker Street Lowell, MA 01854

Phone 978-569-1111 Fax 978-569-1112

HYDRANT FLOW TEST

Customer: 1165R MASS MA PROPERTY, LLC 11/12/2020
Address: ONE POST OFFICE SQUARE (26TH FLOOR)
City / Town: BOSTON State: MA ZIP: 02119

Property Name: 1165R MASS AVE.
Address: 1165R MASS AVE.
City / Town: ARLINGTON State: MA ZIP: 02474

HYDRANT INFO

Make: WATEROUS Model: 5510 YEAR: 2015
Location: 1165 MASS AVE.

HYDRANT STATIC: 145 PSI
FLOW RESIDUAL: 135 PSI
PITOT READING: 40 PSI
FLOW (GPM): 1060 GPM
DISTANCE BETWEEN HYDRANTS (FEET): 360'
ELEVATION OF FLOW: 5 DEGREES
SIZE OF CITY MAIN: 12"
SIZE OF BUTT ON HYDRANT: 2-1/2"
CIRCULATING OR DEADEND MAIN: Circulating

Circulating ☒

Dead End ☐

COMMENTS:

BOTH HYDRANTS OPERATED AND DRAINED PROPERLY

TECHNICIAN: DAVE NIEMI DATE: 11/12/2020 TIME: 4:00AM

filename: S:\Accounts\Quality Fire\1165R Mass MA Property LLC\MA Arlington 1165R Mass Ave. 1165R Mass Ave. Hydrant Flow Test 11.12.2020.

Boutchia, Paul

From: Bruneau, Jim <JBruneau@bhplus.com>
Sent: Tuesday, November 24, 2020 12:16 PM
To: Boutchia, Paul
Cc: 'Gary Spence'; 'Julia Kew'; StClair, Daniel; Leonard, Jarrett; Horigan, Brendan; Brunelle, David; Bargmann, Joel; Jesse Johnson; Andy Platt; Sean Cashman (sean.cashman@aberthawcc.com)
Subject: [EXTERNAL] RE: 1165R - Hydrant Flow Test Report

Paul and Team,

A bit of good news on the water pressure.

-Jim

Hi Jim, this is an excellent result, the pressure and flow is very good. NO need for a fire pump or domestic booster system.

Greg

Gregory B. Wozny, PE, LEED AP
Principal

Wozny/Barbar & Associates, Inc.

1076 Washington Street

Hanover, MA 02339

Tel: 781-826-4144

Fax: 781-924-5792

Cell: 781-424-7319

Jim Bruneau RA, Senior Associate

BARGMANN HENDRIE + ARCHETYPE, INC.

9 Channel Center Street, Suite 300, Boston, MA 02210

617 350 0450 main

617 456 2230 direct